

Tamilnadu Textbook and Educational Services Corporation, Chennai-6

The Pre-bid meeting held on 18.05.2018 at 3.00 p.m. for the
SUPPLY AND INSTALLATION OF FIRE FIGHTING SYSTEM
[1. PUMP HOUSE WITH FIRE HYDRANT SYSTEM
2.SPRINKLER SYSTEM FOR BLOCK B (G+11) FLOORS]

Sl.No	Queries raised	Clarification for Remarks
1.	In the technical bid it has mentioned that the income tax filled must be more than 1 crore, if it is possible of up to 70 lakhs. Please clarify.	The Bid condition as per Tender documents P.No.12 Clause no. 4.2 is confirmed.
2.	Without paying any advance can we get payment against supply of materials, if it is possible well and good	Bid condition is confirmed (as per tender document in P.No. 29. Clause no. 8 (a))
3.	Fire approval	Bid condition is confirmed. (as per P.No.27, Clause no. 6)
4.	Power & water	Will be provided by TNTB&ESC
5.	Storage space	Will be provided by TNTB&ESC
6.	Payment advance required.	Bid condition is confirmed (as per tender document in P. No 29. Clause no. 8 (a))
7.	Samples (pump, motor impossible to keep)	Bid condition is confirmed (as per tender document in P.No 27. Clause no. 6).
8.	Civil work	Will be provided by TNTB&ESC
9.	As so many items involved in this work. It is not practically	Bid condition is confirmed (as

	possible to be a authorised distributor for all the materials. Usually same nature of work done for the value of 60% to 80 % of Estimate value (or) government Registration will be creteria.	per P. No. 12 Clause no. (4.1))
10.	Terrace level booster pump is required or not .	Not necessary
11.	Individual false ceiling detail is required.	Dismantling of false ceiling – Will be carried out by TNTB&ESC.
12.	Fire pump house drawing & site plan.	If the tenderer is successful, before starting, tenderer must produce drawing with pump house, hydrant, hose reel, inflow & outflow pipeline and site plan.
13.	External fire hydrant line pedestal is required or not.	Pipeline should be laid above ground level. i.e 7 feet from the basement. Refer the bill of quantities in the tender document.

S/d
Managing Director
TNTB&ESC